

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES
G.T. Road, Bosepara, Mahesh-1, P.S. - Serampore, Pin -
712202**

Memo No : IND/WB/FES/20202021/24474

DATE: 25/09/2020

From :

**The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.**

To :

**Mother International School
2, Kazi Nazrul Islam Sarani, (Near olympic Ground) , Konnagar, Hooghly-712235
Konnagar F.S., Uttarpara,
Hooghly - 712235 .**

Sub :Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 3 storied building under group Educational at the premises no.- 2, Kazi Nazrul Islam Sarani, (Near olympic Ground) , Konnagar, Hooghly-712235, Uttarpara, Hooghly - 712235

This is in reference to your Application No. IND/WB/FES/20202021/24474,dated 25/09/2020, regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 3 storied building under group Educational at the premises no.- 2, Kazi Nazrul Islam Sarani, (Near olympic Ground) , Konnagar, Hooghly-712235, Uttarpara, Hooghly - 712235.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. No parking will be allowed on the Driveway.

2.The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.

3.To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.

4.Existing Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling & ducts.

1. A fire control room including a closed circuit T.V. system will have to be installed which observes all floors of the buildings.

2.The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the Building.

3.The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.

4.Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.

5.Transformer and Switch Gear room shall be protected with automatic Co2 or D.C.P. Fire extinction confirming I.S. Specification.

6.A crew of trained Fireman under an experience officer shall be maintained round the clock for safety of the building.

7.The system of auto shut down of A.H.U. shall be incorporated with the auto detection and alarm system .

8.First-Aid Fire Fighting system shall be provided as per I.S. Specification.

9.Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.

10. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.

11.Fire Lift of eight passenger capacity shall be provided.

12.Existing lifts shall be treated as fire lift in case of emergency.

13.Periodical flashing of water in the Hydrants and Sprinkler Pipe line shall be made to maintain the efficiency working performance of above mention system.

14.The fire check door shall be sealed with rubber sealing properly in order to prevent the percolation of smock.

15.The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.

16.Each year a certificate is to be obtained from the Divisional Fire Officer, HooghlyDivn, West Bengal Fire & Emergency Services performance of all the life & Fire Safety arrangements and installations of the building.

Divisional Fire Officer
West Bengal Fire & Emergency Services

Signature valid

Digitally signed by SANAT
KUMAR MONDAL
Date: 2020.09.25 15:58:43 IST